



Designation: C1046 – 95 (Reapproved 2021)

Standard Practice for In-Situ Measurement of Heat Flux and Temperature on Building Envelope Components¹

This standard is issued under the fixed designation C1046; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This practice covers a technique for using heat flux transducers (HFTs) and temperature transducers (TTs) in measurements of the in-situ dynamic or steady-state thermal behavior of opaque components of building envelopes. The applications for such data include determination of thermal resistances or of thermal time constants. However, such uses are beyond the scope of this practice (for information on determining thermal resistances, see Practice C1155).

1.2 Use infrared thermography with this technique to locate appropriate sites for HFTs and TTs (hereafter called sensors), unless subsurface conditions are known.

1.3 The values stated in SI units are to be regarded as the standard. The values given in parentheses are for information only.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.*

1.5 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

¹ This practice is under the jurisdiction of ASTM Committee C16 on Thermal Insulation and is the direct responsibility of Subcommittee C16.30 on Thermal Measurement.

Current edition approved Oct. 1, 2021. Published October 2021. Originally approved in 1985. Last previous edition approved in 2013 as C1046 – 95 (2013). DOI: 10.1520/C1046-95R21.

2. Referenced Documents

2.1 *ASTM Standards:*²

C168 Terminology Relating to Thermal Insulation

C518 Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus

C1060 Practice for Thermographic Inspection of Insulation Installations in Envelope Cavities of Frame Buildings

C1130 Practice for Calibration of Thin Heat Flux Transducers

C1153 Practice for Location of Wet Insulation in Roofing Systems Using Infrared Imaging

C1155 Practice for Determining Thermal Resistance of Building Envelope Components from the In-Situ Data

3. Terminology

3.1 *Definitions*—For definition of terms relating to thermal insulating materials, see Terminology C168.

3.2 *Definitions of Terms Specific to This Standard:*

3.2.1 *building envelope component*—a portion of the building envelope, such as a wall, roof, floor, window, or door, that has consistent construction.

3.2.1.1 *Discussion*—For example, an exterior stud wall would be a building envelope component, whereas a layer thereof would not be.

3.2.2 *thermal time constant*—the time necessary for a step change in temperature on one side of an item (for example, an HFT or building component) to cause the corresponding change in heat flux on the other side to reach 63.2 % of its new equilibrium value where one-dimensional heat flow occurs. It is a function of the thickness, placement, and thermal diffusivity (see Appendix X1) of each constituent layer of the item.

3.2.2.1 *Discussion*—

$$t = \tau \text{ when } q(t) = q_1 + (q_2 - q_1) (1 - e^{-t/\tau})$$

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

where:

q_1 = is the previous equilibrium heat flux, and
 q_2 = is the new heat flux after the step change.

3.3 Symbols Applied to the Terms Used in This Standard:

E = measured voltage from the HFT, typically in mV,
 q = heat flux, W/m^2 ($\text{Btu/h}\cdot\text{ft}^2$),
 S = heat-flux transducer conversion factor that relates the output of the HFT, E , to q through the HFT for the conditions of the test, $\text{W/m}^2\cdot\text{V}$ ($\text{Btu/h}\cdot\text{ft}^2\cdot\text{mV}$). This may be a function of temperature, heat flux, and other factors in the environment as discussed in Section 7. This may also be expressed as $S(T)$ to connote a function of temperature,
 T = temperature, K ($^{\circ}\text{C}$, $^{\circ}\text{R}$, or $^{\circ}\text{F}$),
 t = time, s (hours, days), and
 τ = thermal time constant, s (hours, days).

4. Summary of Practice

4.1 Heat flux transducers are installed on or within a building envelope component in conjunction with temperature transducers, as required. Heat flux through a surface is influenced by temperature gradients, thermal conductance, heat capacity, density and geometry of the test section, and by convective and radiative coefficients. The resultant heat fluxes are determined by multiplying a conversion factor S of the HFT by its electrical output. The S values shall have been obtained according to Practice C1130.

5. Significance and Use

5.1 Traditionally, HFTs have been incorporated into laboratory testing devices, such as the heat flow meter apparatus (Test Method C518), that employ controlled temperatures and heat flow paths to effect a thermal measurement. The application of heat flux transducers and temperature transducers to building components in situ can produce quantitative information about building thermal performance that reflects the existing properties of the building under actual thermal conditions. The literature contains a sample of reports on how these measurements have been used (1-8).³

5.2 The major advantage of this practice is the potential simplicity and ease of application of the sensors. To avoid spurious information, users of HFTs shall: (1) employ an appropriate S , (2) mask the sensors properly, (3) accommodate the time constants of the sensors and the building components, and (4) account for possible distortions of any heat flow paths attributable to the nature of the building construction or the location, size, and thermal resistance of the transducers.

5.3 The user of HFTs and TTs for measurements on buildings shall understand principles of heat flux in building components and have competence to accommodate the following:

5.3.1 Choose sensor sites using building plans, specifications and thermography to determine that the measurement represents the required conditions.

5.3.2 A single HFT site is not representative of a building component. The measurement at an HFT site represents the conditions at the sensing location of the HFT. Use thermography appropriately to identify average and extreme conditions and large surface areas for integration. Use multiple sensor sites to assess overall performance of a building component.

5.3.3 A given HFT calibration is not applicable for all measurements. The HFT disturbs heat flow at the measurement site in a manner unique to the surrounding materials (9, 10); this affects the conversion constant, S , to be used. The user shall take into account the conditions of measurement as outlined in 7.1.1. In extreme cases, the sensor is the most significant thermal feature at the location where it has been placed, for example, on a sheet metal component. In such a case, meaningful measurements are difficult to achieve. The user shall confirm the conversion factor, S , prior to use of the HFT to avoid calibration errors. See Section 7.

5.3.4 The user shall be prepared to accommodate non-steady-state thermal conditions in employing the measurement technique described in this practice. This requires obtaining data over long periods, perhaps several days, depending on the type of building component and on temperature changes.

5.3.5 Heat flux has a component parallel to the plane of the HFT. The user shall be able to minimize or accommodate this factor.

6. Apparatus

6.1 Essential equipment for measuring heat flux and temperature includes the following:

6.1.1 *Heat Flux Transducer*—A rigid or flexible device (see Appendix X2) in a durable housing, composed of a thermopile (or equivalent) for sensing the temperature difference across a thin thermal resistive layer, which produces a voltage output that is a function of the corresponding heat flux and the geometry and material properties of the HFT.

NOTE 1—All calibrations relating output voltage to heat flux shall conform to Practice C1130 and pertain to the measurement at hand. Manufacturers' calibrations supplied with HFTs often do not conform with Practice C1130. Obtain the HFT conversion factor as described in Section 8 of Practice C1130.

6.1.2 *Temperature Transducer*—A thermocouple, resistance thermal device (RTD), or thermistor for measuring temperatures on or within the construction, or for measuring air temperatures. Some HFTs incorporate thermocouples.

6.1.3 *Recorder*—An instrument that reads sensor output voltage and records either the voltage, heat flux, or temperature values calculated from appropriate formulas, with durable output (for example, magnetic tape, magnetic disk, punch tape, printer, or plotter).

6.1.4 *Attachment Materials*—Pressure-sensitive tape, adhesive, or other means for holding heat flux and temperature transducers in place on the test surface or within the construction.

6.1.5 *Thermal Contact Materials*—Gel toothpaste, heat sink grease, petroleum jelly, or other means to improve thermal contact between an irregular surface and a smooth HFT.

³ The boldface numbers in parentheses refer to the list of references at the end of this practice.