



Designation: D5392 – 19

Standard Test Method for Isolation and Enumeration of *Escherichia coli* in Water by the Two-Step Membrane Filter Procedure¹

This standard is issued under the fixed designation D5392; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

1. Scope

1.1 This test method describes a membrane filter (MF) procedure for the detection and enumeration of *Escherichia coli*, a bacterium found exclusively in the feces of humans and other warm-blooded animals. The presence of these microorganisms in water is an indication of fecal pollution and the possible presence of enteric pathogens. These bacteria are found in water and wastewater in a wide range of densities. The detection limit of this procedure is one colony forming unit (CFU) per volume filtered.

1.2 This test method has been used successfully with temperate fresh and marine ambient waters, and wastewaters. It is the user's responsibility to ensure the validity of this test method for waters of other types.

1.3 The values stated in SI units are to be regarded as standard.

1.4 *This standard does not purport to address all of the safety concerns, if any, associated with its use. It is the responsibility of the user of this standard to establish appropriate safety, health, and environmental practices and determine the applicability of regulatory limitations prior to use.* For specific hazard statements, see Section 9.

1.5 *This international standard was developed in accordance with internationally recognized principles on standardization established in the Decision on Principles for the Development of International Standards, Guides and Recommendations issued by the World Trade Organization Technical Barriers to Trade (TBT) Committee.*

2. Referenced Documents

2.1 ASTM Standards:²

D1129 Terminology Relating to Water

D1193 Specification for Reagent Water

D3370 Practices for Sampling Water from Flowing Process Streams

D3870 Practice for Establishing Performance Characteristics for Colony Counting Methods in Microbiology (Withdrawn 2000)³

D5465 Practices for Determining Microbial Colony Counts from Waters Analyzed by Plating Methods

3. Terminology

3.1 Definitions:

3.1.1 For definitions of terms used in this standard, refer to Terminology D1129.

3.2 Definitions of Terms Specific to This Standard:

3.2.1 *Escherichia coli* (*E. coli*), *n*—a species of bacteria that is a member of the total coliform group and known to originate in the feces of warm-blooded animals.

3.3 Performance Characteristics (Practice D3870):

3.3.1 *accuracy*, *n*—the proportion of the observed count to the true density of a sample.

3.3.2 *bias*, *n*—the persistent positive or negative deviation of the average value of the test method from the assumed or accepted true value.

3.3.3 *precision*, *n*—the degree of agreement of repeated measurements of the same parameter expressed quantitatively as the standard deviation or as the 95 % confidence limits of the mean computed from the results of a series of controlled determinations.

3.3.4 *specificity*, *n*—the ability of a test method to select or distinguish, or both, the target bacteria in the same water sample; the specificity characteristic of the method is usually reported as the percent of false positive and false negative results.

3.3.5 *upper counting limit (UCL)*, *n*—that colony count above which there is an unacceptable counting error; the error may be due to overcrowding or antibiosis.

¹ This test method is under the jurisdiction of ASTM Committee D19 on Water and is the direct responsibility of Subcommittee D19.24 on Water Microbiology.

Current edition approved April 1, 2019. Published April 2019. Originally approved in 1993. Last previous edition approved in 2014 as D5392 – 14. DOI: 10.1520/D5392-19.

² For referenced ASTM standards, visit the ASTM website, www.astm.org, or contact ASTM Customer Service at service@astm.org. For *Annual Book of ASTM Standards* volume information, refer to the standard's Document Summary page on the ASTM website.

³ The last approved version of this historical standard is referenced on www.astm.org.

4. Summary of Test Method

4.1 This two-step test method⁴ provides a direct count of bacterial colonies developing on the surface of the filter when placed on a selective nutrient medium. The water sample is passed through a membrane filter that retains the bacteria. After filtration, the membrane filter containing the bacterial cells is placed on a selective, differential medium, mTEC. The membrane on the medium is first incubated at 35°C for 2 h so that injured or stressed bacteria can be resuscitated and then the medium is incubated at 44.5°C for 22 h. Following incubation, the filter is transferred to a filter pad saturated with urea substrate. After 15 min all yellow or yellow-brown colonies are counted with the aid of 10 to 15× magnifier and a fluorescent lamp.

5. Significance and Use

5.1 This test method is useful for measuring recreational water quality and chlorinated wastewaters, although it can be used for any water suspected of contamination by fecal wastes of warm-blooded animals. The significance of finding *E. coli* in recreational water samples, especially samples obtained from fresh recreational waters, is that there is a risk of gastrointestinal illness, directly related to the *E. coli* density, associated with swimming.⁵

5.2 Since small or large volumes of water or dilutions thereof can be analyzed by the MF technique, a wider range of levels of *E. coli* in water can be detected and enumerated than with other methods.

6. Interferences

6.1 Water with high levels of colloidal or suspended materials can clog the membrane filter pores and prevent filtration. Also, suspended materials cause spreading colonies that could interfere with target colonies and thereby prevent accurate counting.

6.2 Smaller sample size or sample dilution can be used to minimize the interference of turbidity or high background (nontarget) bacterial densities. Replicates of sample volumes or dilutions of sample may be filtered and the results combined. However, the membrane filter techniques may not be applicable to high turbid waters with low bacterial densities.

6.3 In some samples, chemicals may have toxic effects on the target organism.

7. Apparatus

7.1 *Stereoscopic Microscope*, wide-field type with magnification of 10 to 15×.

7.2 *Microscope Lamp*, producing diffuse light from a cool, white fluorescent lamp adjusted to give maximum visibility.

7.3 *Counting Device*, hand tally or electronic.

7.4 *Pipet Container*, stainless steel, aluminum, or borosilicate glass, for glass pipets.

7.5 *Pipets*, sterile, T.D. bacteriological or Mohr, glass or plastic, of appropriate volume.

7.6 *Graduated Cylinders*, 100 to 1000 mL, covered with aluminum foil or kraft paper and sterile.

7.7 *Membrane Filtration Units* (filter base and funnel), glass, plastic, or stainless steel, wrapped in aluminum foil or kraft paper and sterilized.

7.8 *Ultraviolet Unit*, for sterilizing the filtration unit (optional).

7.9 *Line Vacuum, Electric Vacuum Pump, or Aspirator*, for use as a vacuum source. In an emergency or in the field, a hand pump or a syringe equipped with a check valve to prevent the return flow of air, can be used.

7.10 *Flask*, filter, vacuum, usually 1 L, with appropriate tubing. A filter manifold to hold a number of filter bases is optional.

7.11 *Forceps*, straight or curved, with smooth tips to handle filters without damage.

7.12 *Thermometers*, checked against a National Institute of Standards and Technology (NIST) certified thermometer, or one traceable to a NIST thermometer.

7.13 *Petri Dishes*, sterile, plastic, 50 by 12 mm, with tight-fitting lids.

7.14 *Bottles*, milk dilution, borosilicate glass, screw-cap with neoprene liners, marked at 99 mL for 1 to 100 dilutions. Dilution bottles marked at 90 mL or tubes marked at 9 mL may be used for 1 to 10 dilutions.

7.15 *Inoculation Loops*, at least 3-mm diameter, and needles, nichrome or platinum wire, 26 B & S gage, in suitable holders.

7.16 *Incubator*, air, maintained at $35 \pm 0.5^\circ\text{C}$.

7.17 *Incubator, Waterbath*, maintained at $44 \pm 0.2^\circ\text{C}$.

7.18 *Test Tubes*, 150 by 20 mm, borosilicate glass or plastic.

7.19 *Test Tubes*, 75 by 10 mm, borosilicate glass.

7.20 *Caps*, aluminum or autoclavable plastic, for 20-mm diameter test tubes.

7.21 *Test Tubes*, screw-cap, borosilicate glass, 125 by 16 mm or other appropriate size.

8. Reagents and Materials

8.1 *Purity of Reagents*—Reagent grade chemicals shall be used in all tests. Unless otherwise indicated, it is intended that all reagents conform to the specifications of the Committee on

⁴ Dufour, A., Strickland, E., and Cabelli, V., "Membrane Filter Method for Enumerating *Escherichia coli*," *Applied and Environmental Microbiology*, Vol 41, 1981, pp. 1152–1158.

⁵ Cabelli, V. J., Dufour, A. P., Levin, M. A., McCabe, L. J., and Haberman, P. W., "Relationship of Microbial Indicators to Health Effects at Marine Bathing Beaches," *American Journal of Public Health*, Vol 69, 1979, pp. 690–696.