
Specification for
**Electrical safety and performance of
gas fired space heating appliances
with inputs 60 kW to 2 MW**

Spécification pour la sécurité électrique et la performance des appareils
de chauffage d'ambiance marchant au gaz présentant une énergie absorbée
allant de 60 kW à 2 MW

Spezifikation für Elektrosicherheit und Leistung von gasbeheizten
Raumheizgeräten mit Stromaufnahme von 60 kW bis 2 MW

Confirmed December 2011

Contents

	Page		Page
Foreword	Inside front cover	4.17 Resistance to rusting	11
Cooperating organizations	Back cover	4.18 Marking	11
		4.19 Electrical servicing	12
Specification		Appendix	
1. Scope	1	A. Measurement of creepage distances and clearances	13
2. References	1		
3. Definitions	1	Tables	
4. Electrical equipment and wiring	1	1. Size of cable and conduit entries	1
4.1 General	1	2. Conductor cross-sectional areas for which terminals shall be suitable	2
4.2 Supply connections and external cables and cords	1	3. Torque values for screws and nuts	3
4.3 Bushings for cables and cords	1	4. Dimensions of screw-type terminals	3
4.4 Terminals for external conductors	2	5. Dimensions of stud-type terminals	4
4.5 Internal wiring	4	6. Test voltages	5
4.6 Earthing	4	7. Permissible temperature rises for insulation materials	6
4.7 Electrical insulation	5	8. Creepage distances and clearances	8
4.8 Protection against electric shock	6		
4.9 Transformers	7	Figures	
4.10 Plugs and sockets	7	1. Ball-pressure apparatus	9
4.11 Creepage distances and clearances	7	2. Hot-mandrel apparatus	10
4.12 Switches	7	3. Arrangement and dimensions of the electrodes for the tracking test	11
4.13 Screws and connections	7		
4.14 Capacitors	9		
4.15 Lamps and lampholders	9		
4.16 Resistance to heat, fire and tracking	9		

Foreword

This standard has been prepared under the direction of the Gas Standards Committee and specifies requirements for the safety and performance of electrical equipment used in the gas fired space heating appliances dealt with in BS 5978, BS 5990 and BS 5991.

Due account has been taken of experience and current practice, both nationally and internationally.

The requirements for electrical equipment have been taken almost entirely from BS 3456 : Part 101 and are those

requirements considered to be particularly relevant to gas fired space heating appliances.

Additional requirements dealing with aspects not covered in BS 3456 : Part 101, but which are specific to gas fired space heating appliances are also included.

The committee acknowledges its debt to the British Gas Corporation for preparing the initial draft.