

Non controllable backflow preventer with different pressure zones — Family C, type A

The European Standard EN 14367:2005 has the status of a
British Standard

ICS 91.140.60

National foreword

This British Standard was published by BSI. It is the UK implementation of EN 14367:2005.

The UK participation in its preparation was entrusted by Technical Committee B/504, Water supply, to Subcommittee B/504/14, Backflow prevention.

A list of organizations represented on B/504/14 can be obtained on request to its secretary.

The UK Committee would like to comment on the following:

- 1. clause **9.2.2** specifies that all measuring instruments shall have an accuracy of $\pm 2\%$, but this can be too wide compared with the tolerance for the temperature of the test water;
- 2. in Figure 3 the correct orientation of the test sample on the test rig is not given, it is assumed that the inlet end of the device is to the left hand side of the figure;
- 3. two figures have been labelled Figure 4;
- 4. contradictory information is given in clause **9.6.2.1**, it may be assumed that a certified check valve EB conforming to EN 13959 having a closing pressure of 0,5 KPa will take precedence over any other check valve.

The reader is advised to take these statements of B/504 into account when applying this standard.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 October 2006

© BSI 2006

ISBN 0 580 47599 9

Amendments issued since publication

Amd. No.	Date	Comments