

Ventilation for buildings — Energy performance of buildings — Guidelines for inspection of ventilation systems

ICS 91.140.30

National foreword

This British Standard is the UK implementation of EN 15239:2007.

The UK participation in its preparation was entrusted to Technical Committee RHE/2, Ventilation for buildings, heating and hot water services.

A list of organizations represented on this committee can be obtained on request to its secretary.

It should be noted that Article 9 of the Energy Performance of Buildings Directive 2002/91/EC only requires inspection of air conditioning systems of effective rated output of more than 12 kW. The directive defines an air conditioning system as: “a combination of all components required to provide a form of air treatment in which the temperature is controlled or can be lowered, and includes systems which combine such air treatment with the control of ventilation, humidity and air cleanliness.”

BS EN 15240 deals with inspection of air conditioning systems as defined in the above Directive, this standard deals solely with the inspection of “ventilation systems” which at the present time are not a requirement of the Directive.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

Compliance with a British Standard cannot confer immunity from legal obligations.

This British Standard was published under the authority of the Standards Policy and Strategy Committee on 31 July 2008

© BSI 2008

ISBN 978 0 580 55020 1

Amendments/corrigenda issued since publication

Date	Comments