

IEC 61892-2
(Second edition – 2012)

Mobile and fixed offshore units – Electrical installations –

Part 2: System design

C O R R I G E N D U M 1

4.2.6.

Delete the Note.

Replace the existing text in this clause with the following new text:

If main power is supplied externally, the arrangement is to be such that the requirement of 4.2.3 b) is met by a local generator, or alternatively a second independent external supply. The local generator shall not be the emergency generator.